

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1597:122 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: TEPG-US, 91 Technology Drive, Westminter, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models "*TrueAlert non-addressable*" 4904-9331, 4904-9342, 4904-9332, 4904-9343, 4904-9333 and 4904-9344 synchronized strobe lights.

Models "*TrueAlert non-addressable*" 4904-9168, 4904-9171, 4904-9169, 4904-9172, 4904-9170 and 4904-9173 non-synchronized strobe lights.

Models "*TrueAlert addressable*" 4904-9350, 4904-9351, 4904-9352, 4904-9353, 4904-9354, 4909-9355 synchronized strobe lights.

Models "*TrueAlert addressable*" 4904-9356, 4904-9357, 4904-9358, 4904-9359, 4904-9360, 4909-9361 synchronized strobe lights.

Model T372-9802 sync control module.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 4904-9331, -9342, -9350, -9353, -9356, -9359, -9168, -9171: 15cd, 1 Hz.
4904-9332, -9343, -9351, -9354, -9357, -9360, -9169, -9172: 75cd, 1 Hz.
4904-9333, -9344, -9170, -9173, -9352, -9355, -9358, -9361: 110cd, 1 Hz.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Intended for indoor use and wall mounting only.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used with listee's separately listed fire alarm control units. For "*TrueAlert non-addressable*" synchronized strobes, Model T372-9802 sync control module must be used.

XLf: 7125-0026:235

04-09-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager